



COLEMANCABLE

Toll-Free (800) 323-9355

Wiring The World

Fax: (847) 689-1192


PRODUCT DATA SHEET

PART NUMBER: 55304
DESCRIPTION: 18/4 SOLID CL2 THERMOSTAT CABLE
CONSTRUCTION: This cable consists of four bare copper insulated conductors with an overall jacket.
APPROVALS: UL Standard 13, NEC Article 725.
APPLICATION: Class 2 Power Limited Circuit Cable Used In Thermostat Control Applications

Construction Parameters:

Conductor	18 AWG Bare Copper
Stranding	Solid
Insulation Material	Polypropylene
Insulation Thickness	0.006" Nom.
Insulated Conductor Diameter	0.052" Nom.
Number of Conductors	4
Lay Length	Parallel
Jacket Material	PVC
Jacket Thickness	0.014" Nom.
Overall Cable Diameter	0.154" Nom.
Approximate Cable Weight	27.5 Lbs/1M' Nom.
Flame Rating	UL 1581 Vertical Tray Flame Test

Cable Cross-Section



Electrical & Environmental Properties:

Temperature Rating	-20°C to 60°C
Operating Voltage	150V Voltage Rating Per National Electric Code Article 725
Capacitance Between Conductors @ 1 KHz	25 pF/ft Nom.
Capacitance Between Conductors to Shield @ 1 KHz	-----
DC Resistance per Conductor @ 20°C	6.32 Ohms/1M' Nom.

Insulation Colors	Red White Green Blue
Jacket Color	Brown (Other colors available for minimum order)

Legend (Surface Ink Print)	COLEMAN CABLE 55304 18 AWG 4/C C(ETL)US (ETL CODE) TYPE CL2 BAROSTAT II SUN RES -- TYPE CMH FT1
----------------------------	--

On special orders, the customer will accept all factory lengths and +/- 10 percent of total order requested.
 The information presented here is, to the best of our knowledge, is true and accurate. However, since conditions of use are beyond our control, all recommendations or suggestions are presented without guarantee or responsibility on our part. We disclaim all liability in connection with the use of information contained herein or otherwise.

This specification is proprietary intellectual property of Coleman Cable. Any information contained herein shall not be disclosed to any party without written consent of Coleman Cable.

Customer Name _____
 Customer Approval _____

Specification Issue Date: September 22, 2003